

March 18, 2008

ADDENDUM NO. 1

TO

THE PLANS AND SPECIFICATIONS

FOR THE

**SAN JOSE/SANTA CLARA WATER POLLUTION CONTROL PLANT
FY 2007-08 CAPITAL IMPROVEMENT PROGRAM
DAF PRESSURE RETENTION TANKS AND VALVES REPLACEMENT PROJECT – PHASE II**

Notice is hereby given that the following revisions, additions and/or deletions are hereby made of, and incorporated into the Specifications for the SAN JOSE/SANTA CLARA WATER POLLUTION CONTROL PLANT FY 2007-08 CAPITAL IMPROVEMENT PROGRAM DAF PRESSURE RETENTION TANKS AND VALVES REPLACEMENT PROJECT – PHASE II.

IMPORTANT

THIS ADDENDUM MUST BE ACKNOWLEDGED WHEN YOUR BID IS SUBMITTED. FAILURE TO ACKNOWLEDGE THE ADDENDUM MAY CONSTITUTE GROUNDS FOR REJECTION OF THE BID.

INSTRUCTIONS:


- 1. TABLE OF CONTENTS, PAGE 5, under Division 16 – ELECTRICAL, add “16412 Low Voltage Circuit Breakers”.**
- 2. SECTION 15100, VALVES AND OPERATORS, PAGE 15100-8, under 3.02 INSTALLATION, delete part F “For electricfurnished valves.” in its entirety.**

The bidder must sign this Addendum No. 1 in the space provided below and return one signed copy with the bid. Failure to return the signed copy with the bid document shall not relieve the bidder of the obligation to include this addendum in the bid proposal.

Bidder's Name

Signature and Title of Bidder

Approved by:



Bhavani Yerrapotu, P.E.
Division Manager
Technical Support Services
SJ/SC Water Pollution Control Plant

Date

THIS ADDENDUM CONTAINS ONE (1) PAGE