



The property line cleanout/piping shall be laid on a firm bed of $\frac{3}{4}$ inch base rock (before inspection)

Property line cleanout/piping shall have a minimum cover of 4 inches of $\frac{3}{4}$ inch base-rock, then native dirt. The $\frac{3}{4}$ inch base-rock shall be at jobsite and shall be installed after final inspection.